E PLUS BUILDING PRODUCTS PTY LTD AND DAVCOR GROUP PTY LTD

DOOR HARDWARE ASSESSMENT REPORT

Davcor door hardware in E-core doorsets

Report number: FAS220275
Revision: DHAR1.8
Issued date: 19 December 2025 Expiry date: 30 November 2027

JENSEN HUGHES

jensenhughes.com/pacific

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Quality management

Revision	Date	Revision Description		
DHAR1.0	Issue: 25 Nov 2022	Initial issue.		
		Prepared	**Reviewed**	**Authorised**
		Mohammed Mutafi	Omar Saad	Mahmoud Akl
DHAR1.1	Issue: 02 Dec 2022	Updated version with correcting a typographical error.		
		Prepared	**Reviewed**	**Authorised**
		Mohammed Mutafi	Omar Saad	Omar Saad
DHAR1.2	Issue: 29 Jan 2024	Updated version with the addition of Carbine Alpha Deadlatch hardware.		
		Prepared	**Reviewed**	**Authorised**
		Renz Rabusa	Alim Rasel	Alim Rasel
DHAR1.3	Issue: 06 Aug 2024	Report updated to include Mini HD doors and Davcor locksets and hinges.		
		Prepared	**Reviewed**	**Authorised**
		Zakaria Awad	Alim Rasel	Alim Rasel
DHAR1.4	Issue: 29 May 2025	Report updated to include Carbine longreach mortice lock, Carbine emergency turn snib and Carbine round turn snib.		
		Prepared	**Reviewed**	**Authorised**
		Pius Jerome	Mohammed Mutafi	Alim Rasel
DHAR1.5	Issue: 18 Jun 2025	Report updated to include Carbine PA8000 Ascot Entrance set leverset, Carbine PR6000 Rosehill Entrance set leverset, and Carbine PS4000 Sandown Entrance set knob set.		
		Prepared	**Reviewed**	**Authorised**
		Blake Nitschke	Alim Rasel	Alim Rasel
DHAR1.6	Issue: 30 Jun 2025	Report updated to include 127 mm backset for the Carbine P series locksets and three additional Davcor Carbine Longreach snibs and escutcheons: + CRF136-EITF-SS + CRF-EM-SS + CRF-T-SS.		
		Prepared	**Reviewed**	**Authorised**
		Blake Nitschke	Alim Rasel	Alim Rasel
DHAR1.7	Issue: 26 Sep 2025	Report updated with the inclusion of Serens rectangular plate furniture		
		Prepared	**Reviewed**	**Authorised**
		Alim Rasel	Omar Saad	Omar Saad
DHAR1.8	Issue: 19 Dec 2025	Report updated to include the following panic exit devices: + F5000V VERTICAL ROD + F5000R-AF RIM		
		Prepared	**Reviewed**	**Authorised**
	Expiry: 30 Nov 2027	Renz Rabusa	Alim Rasel	Alim Rasel

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Jensen Hughes Fire Testing Pty Ltd
ABN 81 050 241 524
Formerly Warringtonfire Australia Pty Ltd[1]

[1] *Warringtonfire Australia Pty Ltd was acquired by Jensen Hughes in December 2023. Jensen Hughes Fire Testing Pty Ltd is not affiliated, associated, authorised, or endorsed by Warringtonfire Australia Pty Ltd, Warringtonfire Testing and Certification Limited or its "Warringtonfire" or "Certifire" brands.*

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Table of contents

Quality management 2
1.0 Introduction 5
2.0 Baseline test data for full scale doorset 6
3.0 Hardware considered in this report 7
4.0 Additional supporting data considered in this report 11
5.0 Assessment 16
5.1 Door hardware assessment in accordance with AS 1905.1:2015 16
5.2 Applicability of test data to AS 1530.4:2014 16
5.3 Lockset with or without additional furniture 16
5.4 Door closers 21
5.5 Electric strikes 22
5.6 Other locks, latches or bolts 23
5.7 Eye viewers 24
5.8 Additional furniture 25
5.9 Hinges 26
5.10 Panic exit devices 27
6.0 Summary of assessments 29
7.0 Validity 30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

1.0 Introduction

This report documents the findings of the assessment undertaken to determine the fire resistance level (FRL) of Davcor door hardware installed in E-core old and new generation doorsets in accordance with AS 1530.4:2014[2] and AS 1905.1:2015[3] (as applicable).

This report may be used as evidence of suitability in accordance with the requirements of the relevant National Construction Code (NCC) to support the use of the material, product, form of construction or design as given within the scope of this assessment report. It also references test evidence for meeting deemed-to-satisfy (DTS) provisions of the NCC that apply to the assessed systems.

This assessment was carried out at the request of E Plus Building Products Pty Ltd and Davcor Group Pty Ltd. The sponsor details are included in Table 1.

Table 1 Sponsor details

Sponsor	Address
E Plus Building Products Pty Ltd	12-13 Dansu Court Hallam VIC 3803 Australia
Davcor Group Pty Ltd	14 John Hines Avenue Minchinbury NSW 2770 Australia

[2] Standards Australia, 2014, Methods for fire tests on building materials, components and structures – Part 4: Fire-resistance tests for elements of construction, AS 1530.4:2014, Standards Australia, NSW.
[3] Standards Australia, 2015, Components for the protection of openings in fire-resistant walls Fire-resistant doorsets, AS 1905.1:2015, Standards Australia, NSW.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

2.0 Baseline test data for full scale doorset

E-core doorsets were previously tested and reported in test reports FSV 0608, FSV 0609 and TE71229A. Based on the test data, the doorsets are expected to achieve performance as outlined in Table 2.

E-core doorsets were further tested in accordance with AS 1530.4:2014. Based on the test data, the expected performance of the E-core doorsets is assessed in assessment reports FAS200350, FCO3501 and FCO 3430. The tested/assessed performance is summarised in Table 3.

Table 2 Old generation E-core doorset

Test reference	Doorset description	Test/assessment standard	Reference doorset	FRL
FSV 0608	Single leaf plywood faced E-core mini doorset, nominally 35 mm thick	AS 1530.4:19974	A	-/120/30
FSV 0609	Single leaf plywood faced E-core maxi doorset, nominally 45 mm thick	AS 1530.4:1997	B	-/240/30
TE7299A	Two leaf plywood faced E-core maxi doorset, nominally 45 mm thick	AS 1530.4:19855	C	-/240/30
Notes: + The performance of the doorset varied based on their construction and test standards. The relevant doorsets were referenced in section 5.0 as defined in this table.				

Table 3 New generation E-core doorset

Assessment reference	Doorset description	Test standard	Reference doorset	FRL
FAS200350, FCO 3430	Single leaf E-core maxi doorset, nominally 45 mm thick	AS 1530.4:2014	D	Up to -/180/30
	Two leaf E-core maxi doorset, nominally 45 mm thick		E	Up to -/120/30
FAS200350, FCO 3501	Single leaf plywood faced E-core mini doorset, nominally 35 mm thick		F	Up to -/60/30
Notes: + The performance of the doorset varied based on their construction and test standards. The relevant doorsets were referenced in section 5.0 as defined in this table. + Refer to E Plus Building Products Pty Ltd for the latest version of assessment reports FAS200350, FCO 3430 and FCO 3501.				

[4] Standards Australia, 1997, Methods for fire tests on building materials, components and structures – Part 4: Fire-resistance tests of elements of building construction, AS 1530.4:1997, Standards Australia, NSW.

[5] Standards Australia, 1985, Methods for fire tests on building materials, components and structures – Part 4: Fire-resistance tests of elements of building construction, AS 1530.4:1985, Standards Australia, NSW.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

3.0 Hardware considered in this report

A range of door hardware was considered in this report. The hardware considered is listed in Table 4 to Table 11.

Table 4 List of proposed locksets

Item	Model	Description	Backset	Reference test / assessment
1.	DL2700 Trilogy	Digital cylindrical leverset	70 mm	FSP 1520 COA 1634
2.	CDL71 /CDL7100 series	Mechanical digital lockset	60 mm	FSP 1799 COA 2374
3.	CDL7100 & CDL7200	Mechanical digital lockset	60 mm	FSP 1799 FAS210033 DHAR1.0
4.	CDL - SL8SS	Electronic lockset (Tubular latch)	70 mm	EWFA 49234400
5.	CEL - 3IN1 - SL8SN	Electronic lockset (Tubular latch)	70 mm	EWFA 49594800
6.	3000 series	Cylindrical lock	70 mm	FSP 0676
7.	NK2000 series	Digital lock	70 mm	FSP 1086
8.	P series Tiebolt	Cylindrical lock	70 mm	FSP 1165
9.	PN6000 Entry leverset with a cylindrical lock	Entry lever lock set	70 mm	FRT210042 DHAR1.0
10.	PN6000 Entry Leverset with cylindrical lock tested with: + PN6012 Classroom Lever Lockset + PN6062 Storeroom Lever Lockset + PN6082 Passage Lever Lockset + PN6011 Double Cylinder Lever Lockset + PN6095 Communication Passage Lever Lockset + PN6030 Privacy Lever Lockset + PN6075 Dummy Lever + PN6085 Half Cupboard Lever Lockset + PN3000 Entry Knob & Lever Lockset + PN3013 Classroom Knob & Lever Lockset + PN3062 Storeroom Knob & Lever Lockset	Entry lever lock set	70 mm	FAS210049 DHAR1.0
11.	PD7000	Cylindrical lock	70 mm	FSP 0523

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Item	Model	Description	Backset	Reference test / assessment
12.	Davcor Carbine PN6000 Entrance leverset	Leverset furniture	70 mm	FRT220106 R1.0
13.	Carbine Alpha Deadlatch with lever	Lockset	60 mm	FRT230125 DHAR1.0
14.	Carbine Alpha Deadlatch with key lever	Lockset	60 mm	FRT230125 DHAR1.0
15.	Carbine Alpha Deadlatch with knob	Lockset	60 mm	FRT230125 DHAR1.0
16.	Carbine Alpha Deadlatch with key knob	Lockset	60 mm	FRT230125 DHAR1.0
17.	Carbine PY6000 series of cylindrical leversets	Entrance leverset	70 mm	FRT240046 DHAR1.0
18.	Carbine CEL2 BT electronic lockset	Electronic lockset (Tubular latch)	70 mm	FRT240024 DHAR1.0
19.	Davcor Carbine Longreach mortice lock (CSM72-SS) installed with: + Davcor Carbine Crisi round rose furniture and Standard Cogni lever (CRF136-L7-SS) + Davcor Carbine Oval key cylinder (COV SC6(M)) + Carbine Oval Escutcheon (CRF136-EETF-SS) + Carbine Disability lever internal turn snib (CRF136-DT-SS) + Carbine Oval Escutcheon (CRF136-EITF-SS) + Carbine Emergence Turn Snib with indicator (CRF-136-EM-SS) + Carbine Round Turn Snib (CRF136-T-SS)	Mortice lock with furniture	60 mm	FRT121476 R1.0

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Item	Model	Description	Backset	Reference test / assessment
20.	Davcor Carbine Longreach mortice lock (CSM72-SS) installed with: + CSF18-C-SS Rect Furn Std Backset Ext Cyl 7 Lever SS + CSF18-C-7SS- Rect Furn Std Backset Ext Cyl No Lever SS + CSF18-P-SS- Rect Furn Std Backset Ext Plain No Lever SS + CSF18-P-7SS- Rect Furn Std Backset Ext Plain 7 Lever SS + CSF18-IEM-7SS- Rect Furn Std Backset Ext Ind EM Turn 7 Lever SS + CSF19-C-7SS- Rect Furn Std Backset Int Cyl 7 Lever SS + CSF19-P-7SS - Rect Furn Std Backset Int 7 Lever SS + CSF19-DT-SS Rect Furn Std Backset Int Dis Turn 7 lever SS + CSF19- T-SS- Rect Furn Std Backset Int Turn 7 Lever SS	Mortice lock with Serens rectangular plate furniture	60 mm	FRT251763 R1.0
21.	Carbine PA8000 Ascot Entrance set leverset	Cylindrical lock	60mm, 70mm, 127mm	FSP 1165
22.	Carbine PR6000 Rosehill Entrance set leverset	Cylindrical lock	60mm, 70mm, 127mm	FSP 1165
23.	Carbine PS4000 Sandown Entrance set knob set	Cylindrical lock	60mm, 70mm, 127mm	FSP 1165

Table 5 List of proposed door closers

Item	Model	Description	Reference test / assessment
1.	Davcor Carbine CDC-3-S door closer	Surface mounted door closer	FRT210369 DHAR1.0 FAS210379-A
2.	Davcor Carbine CDC-1-S door closer	Surface mounted door closer	FRT210369 DHAR1.0 FAS210379-A
3.	Davcor Carbine CDC-5-S, EN2-6 door closer	Surface mounted door closer	FRT210369 DHAR1.0
4.	Davcor Carbine CDC-5 closer slide track	Closer slide track	FRT210369 DHAR2.0
5.	Davcor Carbine CDC-CA2 door closer	Door Closer	FRT210370 DHAR 1.0
6.	Davcor Carbine CDC-CA1G, CA2G, CA1B & CA2B door closers	Door Closer	FAS210379-B DHAR1.1

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Table 6 List of proposed electric strike

Item	Model	Description	Reference test / assessment
1.	Davcor Carbine CES720S Electric strike	Electric Strike	FRT220106 R1.0
2.	Davcor Carbine CES350-1224 Electric strike	Electric Strike	FRT220106 R1.0
3.	GEM GK-300 series	Electric Strike	FSV 0736

Table 7 List of proposed eye viewer

Item	Model	Description	Reference test / assessment
1.	Ritefit 34 series Door viewer	Eye viewer	FSP 1229

Table 8 List of proposed locks, latches or bolts

Item	Model	Description	Reference test / assessment
1.	Davcor Carbine Night Hawk Pro	Night latch	FRT210369 DHAR3.1
2.	Davcor Carbine Night Hawk Advance	Night latch	FRT210370 DHAR 2.0

Table 9 List of proposed additional furniture

Item	Model	Description	Reference test / assessment
1.	BP & DS series	Blocker plate and Door saver plate	FSP 1165
2.	Latch Guard Blocker Plate BP-LF1MS	Blocker Plate	EWFA 53298100c.1
3.	Latch Guard Blocker Plate BP-NF1MS or BP-MF1MS	Blocker plate	EWFA 53298100 FAS180419.1
4.	Edge Fixed Anti Thrust Plate	Thrust plate	FRT190405d.1
5.	Davcor Carbine Filler Plate CPHD-1SC	Filler Plate	EWFA 53298100b.1
6.	Davcor EVVA Airkey Oval Cylinder retest with a Lockwood 3572C Vestible M	Cylinder knob	FRT200436 DHAR1.0

Table 10 List of proposed hinges

Item	Model	Description	Reference test / assessment
1.	Carbine ball bearing SSS 100 × 100 hinge	Ball bearing hinge	FRT230125 DHAR2.0
2.	Carbine ball bearing SSS 100 × 75 hinge	Ball bearing hinge	FRT240024 DHAR2.0
3.	Carbine fixed pin SSS 100 × 100 hinge	Fixed pin hinge	FRT230143 DHAR2.0
4.	Carbine fixed pin SSS 100 × 75 × 2.5 hinge	Fixed pin hinge	FRT230202 DHAR2.0

Table 11 List of panic exit devices

Item	Model	Description	Reference test / assessment
1.	Davcor F5000V VERTICAL ROD	Panic exit device	FRT240178 DHAR1.0 RTL FT16840.01
2.	Davcor F5000R-AF RIM	Panic exit device	FRT240178 DHAR2.0

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

4.0 Additional supporting data considered in this report

The proposed hardware was assessed based on supporting test data listed in Table 12 and in compliance with AS 1905.1:2015.

Table 12 Additional supporting test data

Test report	Test date	Test scale	Doorset description	Tested hardware	Test duration	Test standard
FSP 1520	20 December 2011	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ TRILOGY DL2700 Series digital lockset + VEML-WPS Series electromagnetic lock + FSH2500 Series electromagnetic shear lock + GK 300 Series electric strike	121 minutes	AS 1530.4:2005
FSP 1799	10 January 2017	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Kone uniswing firesafe automated swing door operator, grade 5 – pushing (Type1) + Carbine CDL71 series mechanical digital lockset	121 minutes	AS 1530.4:2014
EWFA 49234400	14 August 2017	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ Carbine CEL-3IN1-SL8SN Electronic lockset	61 minutes	AS 1530.4:2014
EWFA 49594800	14 July 2017	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ Carbine CEL-3IN1-SL8SN electronic lockset	121 minutes	AS 1530.4:2014
FSP 0676	22 June 1999	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Carbine 3000 series cylindrical lockset + DORMA TS 68 series surface mounted door closer	121 minutes	AS 1530.4:1997
FSP 1086	19 October 2004	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Carbine digital lockset – NK 2000 series + Strike protector plate – ES200/ES2000 series	121 minutes	BS 476: Part22 –1987
FSP 1165	20 March 2007	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Carbine P series tiebolt leverset + Carbine ‘BP’ series blocker plate and carbine ‘DS’ series door saver.	121 minutes	AS 1530.4:1997

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Test report	Test date	Test scale	Doorset description	Tested hardware	Test duration	Test standard
FRT210042	4 March 2021	Pilot scale	Single leaf plywood E-core doorset nominally 38 mm thick	+ Carbine PN6000 entry leverset + Lockwood stainless steel fixed pin hinges LW10075FPSSS	124 minutes	AS 1530.4:2014
FSP 0523	November 1997	Pilot scale	Single leaf plywood E-core doorset nominally 38 mm thick	+ PD7000 leverset + Carbine professional – cyclone series surface mounted door closer + Brodie switch plug	240 minutes	AS 1530.4:1990
FRT220106	14 July 2022	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine CES720S monitored electric strike + Davcor carbine CES350-1224 electric strike + Davcor carbine PN6000 entrance leverset + Stainless steel FP hinges	241 minutes	AS 1530.4:2014
FRT210369	15 November 2021	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine CDC-5-S EN2-6 door closer + Davcor carbine CDC-5-S slide track + Davcor carbine night hawk pro night latch + Trio R1-175F Butt hinges	121 minutes	AS 1530.4:2014
FRT210370	22 November 2021	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ Davcor carbine CDC-CA2 door closer + Davcor carbine night hawk advance night latch + Davcor carbine PE3000 knobset + Trio R1-175F Butt hinges	121 minutes	AS 1530.4:2014

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Test report	Test date	Test scale	Doorset description	Tested hardware	Test duration	Test standard
FSV 0736	1 February 2000	Full scale	Single leaf plywood E-core doorset nominally 45 mm thick	+ Legge pacific 990MF mortice lock fitted to door A + Dalco 4200 series SSS door furniture fitted to door A + Sabre 836 PAS-PC surface mounted door closer fitted to the unexposed face of door A + GEM GK-300 electric strike fitted to the door frame of door A + Dorma BOH-AD 8400 series full vertical rod panic exit device fitted to the exposed face of door B + Dorma TS 83 EN 2-6 surface mounted door closer fitted to the unexposed face of door B	240 minutes	AS 1530.4:1997
FSP 1229	28 September 2006	Pilot scale	Single leaf plywood E-core doorset nominally 38 mm thick	+ Carbine CTL series tubular leverset + Ritefit 34 series door viewer	121 minutes	AS 1530.4:1997
EWFA 53298100	1 June 2018	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ Novas auto flushbolt US32D	121 minutes	AS 1530.4:2014
FRT190405	1 November 2019	Pilot scale	Single leaf plywood faced E-core doorset nominally 35 mm thick	+ Davcore carbine CDC-5-S EN2-6	240 minutes	AS 1530.4:2014
FRT200436	7 January 2021	Pilot scale	Single leaf plywood E-core doorset nominally 38 mm thick	+ Davcor EVVA airkey oval cylinder knob – E. A. PZ. AOV. 36	54 minutes and 30 seconds	AS 1530.4:2014
FRT230125	12 October 2023	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Carbine Alpha Deadlatch with lever – installed on unexposed side + Carbine Alpha Deadlatch with lever – installed on exposed side + Davcor ball bearing 100 × 100 × 2.5 mm SS hinges	120 minutes and 1 second	AS 1530.4:2014

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Test report	Test date	Test scale	Doorset description	Tested hardware	Test duration	Test standard
FRT240046	29 May 2024	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine PY6000-L1 cylindrical leverset (entrance)	120 minutes	AS 1530.4:2014
FRT240024	8 May 2024	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine CEL2 BT electronic lockset + Davcor Carbine CHBB100×75-SSS hinges	120 minutes	AS 1530.4:2014
FRT230143	13 October 2023	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine fixed pin CDFP100×100-SSS hinges	120 minutes	AS 1530.4:2014
FRT230202	26 March 2024	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine fixed pin CHFP100×75×2.5-SSS hinges	120 minutes	AS 1530.4:2014
FRT121476	3 March 2025	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Davcor carbine longreach (CSM72-SS) mortice lock + Davcor Carbine Crisi round rose furniture and a standard Cogni lever (CRF136-L7-SS) + Davcor Carbine Oval key cylinder (COVSC6(M)) and a Carbine oval escutcheon (CRF136-EETF-SS) with turn snib (CRF136-DT-SS)	241 minutes	AS 1530.4:2014
FRT251763 R1.0	24 July 2025	Pilot scale	Single leaf plywood E-core doorset nominally 35 mm thick	+ Carbine Longreach (CSM72-SS) mortice lock + Carbine Serens CSF18-C-7SS Rectangular Furniture Std Backset External Cylinder 7 lever SS – External – with a Carbine Oval Key Cylinder COV-SC6XKA2 + Carbine Serens CSF19-DT-7SS Rectangular Furniture Std Backset Internal Indicating Disability – Internal	240 minutes	AS 1530.4:2014
FRT240178 R1.0	22 August 2024	Full scale	Single leaf plywood faced E-core Maxi doorset, nominally 45 mm thick	+ Davcor F5000V VERTICAL ROD panic exit device	120 minutes	AS 1530.4:2014

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Test report	Test date	Test scale	Doorset description	Tested hardware	Test duration	Test standard
RTL FT16840.01	22 August 2025	Full scale	Single leaf plywood faced E-core Maxi doorset, nominally 38 mm thick	+ Davcor F5000V VERTICAL ROD panic exit device	120 minutes	AS 1530.4:2014

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

5.0 Assessment

5.1 Door hardware assessment in accordance with AS 1905.1:2015

The E-core doorsets were tested in a range of fire resistance tests. The expected performance of the E-core doorset based on these tests and subsequent assessments –FAS200350, FCO3501 and FCO 3430 – are summarised in Table 2 and Table 3. It should be noted that, FCO3501 and FCO 3430 were issued by Infrastructure Technologies. Jensen Hughes has not verified the outcome of these assessment reports. However, for the purpose of this report, it is assumed that the outcomes are accurate.

This report needs to be read in conjunction with test/assessment reports listed in Table 2 and Table 3. As such, the validity of this report is conditional upon the validity of FCO3501 and FCO 3430. Any changes or updates to FAS200350, FCO3501 and FCO 3430 may therefore impact the outcome of this report.

As per section 4 of AS 1905.1:2015, door hardware can be assessed based on additional pilot scale or full-scale tests if conducted in accordance with AS 1530.4. The proposed hardware listed in section 3.0 was tested either in full or pilot scale. The test outcomes are summarised in Table 12 . Based on expected doorset performance listed in Table 2 and Table 3, and pilot/full scale test data summarised in Table 12, the proposed hardware is assessed in compliance with section 4 of AS 1905.1:2015.

This assessment is conditional upon the operational characteristics and materials of the doorset complying with section 2 of AS 1905.1:2015. The field of application of the hardware included in this report is defined by the field of application of the doorset that the door hardware is installed on.

5.2 Applicability of test data to AS 1530.4:2014

It is noted that some full scale or pilot scale tests were conducted in accordance with AS 1530.4:1990, AS 1530.4:1997 or AS 1530.4:2005. The stipulations provided in Appendix B11 of AS 1530.4:1990, AS 1530.4:2005 and AS 1530.4:2014 are not appreciably different. Therefore, the pilot scale test results can be used to assess the fire resistance performance of the hardware if tested in accordance with AS 1530.4:2014.

5.3 Lockset with or without additional furniture

5.3.1 Assessment based on pilot/full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of locksets based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

It is noted that, some locksets included additional furniture. In such case, the furniture was tested as part of the pilot scale or full-scale tests. Any variation in surface mounted furniture is discussed in section 5.3.2.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitute integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of each lockset based on the above criteria is noted.

As the proposed locksets with or without additional furniture (as applicable) did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, substituting the locksets with or without additional furniture (as applicable) for the hardware tested in the referenced doorsets listed in Table 2 and Table 3 are

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

not expected to affect their performance. Based on the above, the proposed locksets listed in Table 4 are positively assessed. Variations from the tested locksets are discussed in sections 5.3.2, 5.3.3 and 5.3.4.

5.3.2 Variation in surface mounted furniture

The proposed locksets included variations for surface mounted furniture in the form of levers, knobs or escutcheon plates. AS 1530.4:2014 clause 7.9.7(l) states: *'Where locksets or latchsets are operated by a steel shaft, their surface-mounted furniture may be varied provided—*

(i) the melting point of any part is not reduced.

(ii) any replacement handle or knob is not so massive or asymmetrical as to introduce a turning moment about the operating shaft which exceeds 0.07 Nm.

(iii) any replacement lever handle is not so massive or asymmetrical as to increase the turning moment about the operating shaft by more than 10%.

(iv) any replacement escutcheon plate adequately covers any hole in the door leaf formed to accommodate the lockset or latchset but does not increase the area of the face of the door leaf covered by the escutcheon by more than 20%.

The proposed locksets with surface mounted furniture that vary from the tested system all satisfied clauses 7.9.7 (l) (i), (ii), (iii) and (iv) of AS 1530.4:2014 as appropriate. Based on the above, the proposed variations in surface mounted furniture are positively assessed.

5.3.3 Variation in operating mechanism

The proposed locksets included variations in operating mechanisms from the tested specimen. AS 1530.4:2014, clause 7.9.7(i) and (j) state that:

(i) Changes may be made in the operating characteristics of latchset or lockset hardware, provided the changes do not require modification of the door leaf or door frame and changes to the functions of the latchsets involving the operating mechanism.

(j) Changes may be made to the materials of the essential latching components, provided the melting point of any part is the same or higher.

It has been confirmed through a survey conducted by Jensen Hughes that the variations in the operating mechanism did not require modification of the door leaf and did not require changes to the function of the latchset. Additionally, the melting point of any part was not reduced. Based on the above, variation in the operating mechanisms of the locksets is positively assessed.

5.3.4 Variation in backset

It is proposed that the backset of locksets be varied. AS 1530.4:2014, clause 7.9.7(g) and (h) states that:

(g) The backset of the mortice lockset or latchset may be reduced.

(h) The backset of a cylindrical lockset or latchset may be varied, provided no additional encroachment is made on any structural framework of the door leaf and the fixing method remains identical.

Based on the above, the reduction in backset of mortice lock is positively assessed.

For cylindrical locksets, it was confirmed through survey that no additional encroachment was needed to be made on the leaf and the fixing method remained unchanged. Based on the above, variation in the backset of the cylindrical lock is also positively assessed.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

5.3.5 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed locksets listed in Table 13 are capable of achieving the FRLs listed in Table 13 – if they are fitted in the referenced E-core doorsets.

Table 13 Fire resistance level of locksets installed in E-core old and new generation doorset

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	Backset	FRL
1.	DL2700 Trilogy	Digital cylindrical leverset	A, B, C, D, E, F	70 mm	-/60/30
2.	CDL71 /CDL7100 series	Mechanical digital lockset	A, B, C, D, E, F	60 mm	-/120/30
3.	CDL7100 & CDL7200	Mechanical digital lockset	A, B, C, D, E, F	60 mm	-/120/30
4.	CDL - SL8SS	Electronic lockset (Tubular latch)	A, B, C, D, E, F	70 mm	-/60/30
5.	CEL - 3IN1 - SL8SN	Electronic lockset (Tubular latch)	A, B, C, D, E, F	70 mm	-/60/30
6.	3000 series	Cylindrical lock	A, B, C, D, E, F	70 mm	-/120/30
7.	NK2000 series	Digital lock	A, B, C, D, E, F	70 mm	-/120/30
8.	P series Tiebolt	Cylindrical lock	A, B, C, D, E, F	70 mm	-/120/30
9.	PN6000 Entry leverset with a cylindrical lock	Entry lever lock set	A, B, C, D, E, F	70 mm	-/120/30
10.	PN6000 Entry Leverset with cylindrical lock tested with: + PN6012 Classroom Lever Lockset + PN6062 Storeroom Lever Lockset + PN6082 Passage Lever Lockset + PN6011 Double Cylinder Lever Lockset + PN6095 Communication Passage Lever Lockset + PN6030 Privacy Lever Lockset + PN6075 Dummy Lever + PN6085 Half Cupboard Lever Lockset + PN3000 Entry Knob & Lever Lockset + PN3013 Classroom Knob & Lever Lockset + PN3062 Storeroom Knob & Lever Lockset	Entry lever lock set	A, B, C, D, E, F	70 mm	-/120/30
11.	PD7000	Cylindrical lock	B, C, D, E	70 mm	-/240/30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	Backset	FRL
12.	Davcor Carbine PN6000 Entrance leverset	Leverset furniture	A, B, C, D, E, F	70 mm	-/240/30
13.	Carbine Alpha Deadlatch with lever	Lockset	A, B, C, D, E, F	60 mm	-/120/30
14.	Carbine Alpha Deadlatch with key lever	Lockset	A, B, C, D, E, F	60 mm	-/120/30
15.	Carbine Alpha Deadlatch with knob	Lockset	A, B, C, D, E, F	60 mm	-/120/30
16.	Carbine Alpha Deadlatch with key knob	Lockset	A, B, C, D, E, F	60 mm	-/120/30
17.	Carbine PY6000 series of cylindrical leversets	Entrance leverset	A, B, C, D, E, F	70 mm	-/120/30
18.	Carbine CEL2 BT electronic lockset	Electronic lockset (Tubular latch)	A, B, C, D, E, F	70 mm	-/120/30[a]
19.	Davcor Carbine Longreach mortice lock (CSM72-SS) installed with: + Davcor Carbine Crisi round rose furniture and Standard Cogni lever (CRF136-L7-SS) + Davcor Carbine Oval key cylinder (COV SC6(M)) + Carbine Oval Escutcheon (CRF136-EETF-SS) + Carbine Disability lever internal turn snib (CRF136-DT-SS) + Carbine Oval Escutcheon (CRF136-EITF-SS) + Carbine Emergence Turn Snib with indicator (CRF-136-EM-SS) + Carbine Round Turn Snib (CRF136-T-SS)	Mortice lock with furniture	A, B, C, D, E, F	60 mm	-/240/30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	Backset	FRL
20.	Davcor Carbine Longreach mortice lockb (CSM72-SS) installed with: + CSF18-C-SS Rect Furn Std Backset Ext Cyl 7 Lever SS + CSF18-C-7SS- Rect Furn Std Backset Ext Cyl No Lever SS + CSF18-P-SS- Rect Furn Std Backset Ext Plain No Lever SS + CSF18-P-7SS- Rect Furn Std Backset Ext Plain 7 Lever SS + CSF18-IEM-7SS- Rect Furn Std Backset Ext Ind EM Turn 7 Lever SS + CSF19-C-7SS- Rect Furn Std Backset Int Cyl 7 Lever SS + CSF19-P-7SS - Rect Furn Std Backset Int 7 Lever SS + CSF19-DT-SS Rect Furn Std Backset Int Dis Turn 7 lever SS + CSF19- T-SS- Rect Furn Std Backset Int Turn 7 Lever SS	Mortice lock with Serens rectangular plate furniture	A, B, C, D, E, F	60 mm	-/240/30
21.	Carbine PA8000 Ascot Entrance set leverset	Cylindrical lock	A, B, C, D, E, F	60mm, 70mm, 127mm	-/120/30
22.	Carbine PR6000 Rosehill Entrance set leverset	Cylindrical lock	A, B, C, D, E, F	60mm, 70 mm, 127mm	-/120/30
23.	Carbine PS4000 Sandown Entrance set knob set	Cylindrical lock	A, B, C, D, E, F	60mm, 70mm, 127mm	-/120/30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	Backset	FRL

Notes:

a. Direction of exposure is limited to the tested direction. The battery pack must be installed on the exposed side as tested.

b. The mortice lock contains a function that, when engaged, extends within the strike plate further than when the door is open – under normal function. It is possible, whether deliberate or unintentional, to trigger the lock so that the latch extends to the full position when the door is not latched. The fully extended latch has the potential of not latching when the door leaf swings shut, thereby contravening Clause 2.1.4.2 of AS1905.1:2015. Therefore, this functionality has to be deactivated to achieve an FRL.

- The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
- The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.4 Door closers

5.4.1 Assessment based on pilot / full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of door closers based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitutes integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of the closers based on the above criteria is noted.

As the proposed closers did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, substituting the closers for the hardware tested in the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed closers listed in Table 5 are positively assessed.

It is noted that the name of some closers has changed for marketing purposes. In such instances, the manufacturer has confirmed that the closer construction remains identical to the tested closer. Any variations from the tested closer are discussed under sections 5.4.2 and 5.4.3.

5.4.2 Variation in closer dimensions

The proposal included closers that are smaller in dimension than the tested closers. AS 1530.4:2014 clause 7.9.7 states that:

(e) An alternative closer manufactured by the same manufacturer and of smaller size closer in the same series of the closer may be used, provided the closer–

(i) is manufactured from the same materials;

(ii) has the same operating mechanism design; and

(iii) uses the same hydraulic fluids.

It has been confirmed by the manufacturer that the proposed closers are manufactured from the same materials, have the same operating mechanism design, and do not vary in hydraulic fluid. The only variation

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

in the closer series is that of a reduction in size. Based on the above, the reduction in closer size is positively assessed.

5.4.3 Sliding channel

The proposed closers included a parallel arm and slide track. The hardware was tested with both, parallel arm, and slide track. Neither the parallel arm nor slide track hardware negatively impacted the performance of the doorset. As such, the surface mounted door closers may be optionally installed with either a parallel arm or slide track configuration.

5.4.4 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed closers listed in Table 14 are capable of achieving the FRLs listed in Table 14 – if they are fitted in the referenced E-core doorsets.

Table 14 Fire resistance level of closers installed in E-core old and new generation doorset

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	Davcor Carbine CDC-3-S door closer	Surface mounted door closer	A, B, C, D, E, F	-/120/30
2.	Davcor Carbine CDC-1-S door closer	Surface mounted door closer	A, B, C, D, E, F	-/120/30
3.	Davcor Carbine CDC-5-S, EN2-6 door closer	Surface mounted door closer	A, B, C, D, E, F	-/120/30
4.	Davcor Carbine CDC-5 closer slide track	Closer slide track	A, B, C, D, E, F	-/120/30
5.	Davcor Carbine CDC-CA2 door closer	Door Closer	A, B, C, D, E, F	-/120/30
6.	Davcor Carbine CDC-CA1G, CA2G, CA1B & CA2B door closers	Door Closer	A, B, C, D, E, F	-/120/30

Notes:

+ The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
+ The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.5 Electric strikes

5.5.1 Assessment based on pilot scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of electric strikes based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

the test constitute integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of the electric strike based on the above criteria is noted.

As the proposed door electric strike did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, substituting the electric strike for the items tested in the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed electric strike listed in

Table 6 is positively assessed.

5.5.2 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed electric strikes listed in Table 15 are capable of achieving the FRLs listed in Table 15 – if fitted in the referenced E-core doorsets.

Table 15 Fire resistance level of electric strikes installed in E-core old and new generation doorset

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	Davcor Carbine CES720S Electric strike	Electric Strike	A, B, C, D, E, F	-/240/30
2.	Davcor Carbine CES350-1224 Electric strike	Electric Strike	A, B, C, D, E, F	-/240/30
3.	GEM GK-300 series	Electric Strike	B, C, D, E	-/240/30

Notes:

+ The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
+ The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.6 Other locks, latches or bolts

5.6.1 Assessment based on pilot/full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of locks, latches and bolts based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitute integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of the proposed locks, latches and bolts based on the above criteria is noted.

As the proposed locks, latches and bolts did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, adding the proposed locks, latches and bolts as an additional item of hardware in the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed locks, latches and bolts listed in Table 8 are positively assessed.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

5.6.2 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed locks, latches and bolts listed in Table 16 are capable of achieving the FRLs listed in Table 16 – if fitted in the referenced E-core doorsets.

Table 16 Fire resistance level of additional locks, latches and bolts installed in E-core old and new generation doorset

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	Davcor Carbine Night Hawk Pro	Night latch	A, B, C, D, E, F	-/120/30
2.	Davcor Carbine Night Hawk Advance	Night latch	A, B, C, D, E, F	-/120/30
Notes: + The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3. + The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.				

5.7 Eye viewers

5.7.1 Assessment based on pilot/full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of eye viewer based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitute integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of the eye viewer based on the above criteria is noted.

As the proposed eye viewer did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, adding the eye viewer as an additional item of hardware in the referenced doorsets listed in Table 2 and Table 3is not expected to affect their performance. Based on the above, the proposed eye viewer listed in Table 7 is positively assessed.

5.7.2 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed eye viewer listed in Table 17 is capable of achieving the FRLs listed in Table 17 – if fitted in the referenced E-core doorsets.

Table 17 Fire resistance level of eye viewers installed in E-core old and new generation doorset

Item	Model	Description as defined in Table 2 and Table 3	Reference doorset	FRL
1.	Ritefit 34 series Door viewer	Eye viewer	A, B, C, D, E, F	-/120/30
Notes:				

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

- The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
- The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.8 Additional furniture

5.8.1 Assessment based on pilot/full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of surface mounted furniture based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4. As such, in addition to the full-scale tests listed in Table 2 and Table 3, the pilot scale or full-scale tests listed in Table 12 form the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitute integrity failure. From the pilot scale or full-scale tests, the attained duration of integrity performance of the furniture based on the above criteria is noted.

As the proposed furniture did not cause failure up to the noted timeframes in the pilot scale tests or full-scale tests, substituting the proposed furniture for the tested hardware in the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed furniture listed in Table 9 is positively assessed.

5.8.2 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed furniture listed in Table 18 are capable of achieving the FRLs listed in Table 18 – if fitted in the referenced E-core doorsets.

Table 18 Fire resistance level of additional Furniture installed in E-core old and new generation doorset

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	BP & DS series	Blocker plate and Door saver plate	A, B, C, D, E, F	-/120/30
2.	Latch Guard Blocker Plate BP-LF1MS	Blocker Plate	A, B, C, D, E, F	-/120/30
3.	Latch Guard Blocker Plate BP-NF1MS or BP-MF1MS	Blocker plate	A, B, C, D, E, F	-/120/30
4.	Edge Fixed Anti Thrust Plate	Thrust plate	A, B, C, D, E, F	-/240/30
5.	Davcor Carbine Filler Plate CPHD-1SC	Filler Plate	A, B, C, D, E, F	-/120/30
6.	Davcor EVVA Airkey Oval Cylinder retest with a Lockwood 3572C Vestible M	Cylinder knob	A, B, C, D, E, F	-/45/30
Notes:				

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

- The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
- The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.9 Hinges

5.9.1 Assessment based on pilot/full scale test

Section 4.5 of AS 1905.1:2015 permits the assessment of hinges based on a pilot scale or full-scale fire resistance test in accordance with AS 1530.4:2014. As such, in addition to the full-scale tests listed in Table 2 and Table 3, pilot scale or full-scale tests listed in Table 12 for the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test constitutes integrity failure. From the pilot scale tests, the attained duration of integrity performance of the hinges based on the above criteria is noted.

As the proposed hinges did not cause failure up to the noted timeframes in the pilot scale or full scale tests, adding the hinges as an additional item of hardware in the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed hinges listed in Table 10 are positively assessed.

5.9.2 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the proposed hinges listed in Table 19 are capable of achieving the FRLs listed in Table 19 – if fitted in the referenced E-core doorsets.

Table 19 Fire resistance level of hinges installed in old and new generation E-core doorsets

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	Carbine ball bearing SSS 100 × 100 hinge	Ball bearing hinge	A, B, C, D, E, F	-/120/30
2.	Carbine ball bearing SSS 100 × 75 hinge	Ball bearing hinge	A, B, C, D, E, F	-/120/30
3.	Carbine fixed pin SSS 100 × 100 hinge	Fixed pin hinge	A, B, C, D, E, F	-/120/30
4.	Carbine fixed pin SSS 100 × 75 × 2.5 hinge	Fixed pin hinge	A, B, C, D, E, F	-/120/30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

Notes:

- The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
- The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

5.10 Panic exit devices

5.10.1 Assessment based on full scale test

Section 4.4 of AS 1905.1:2015 permits the assessment of panic exit devices based on a full-scale fire resistance test in accordance with AS 1530.4:2014. As such, in addition to the tests listed in Table 2 and Table 3, the full-scale test listed in Table 12 for the basis of this assessment.

AS 1530.4:2014 states that either sustained flaming on the surface of the unexposed face for 10 seconds or longer, ignition of a cotton pad, gap gauge failure, or the latching mechanism being disengaged at the end of the test, constitutes integrity failure. From the full-scale test, the attained duration of integrity performance of the panic exit device based on the above criteria is noted.

As the proposed panic exit devices did not cause failure up to the noted timeframe in the full-scale test, adding the panic exit device as an additional item of hardware to the referenced doorsets listed in Table 2 and Table 3 is not expected to affect their performance. Based on the above, the proposed panic exit devices listed in Table 20 are positively assessed.

5.10.2 Devices with a horizontal bar

AS 1905.1:2015 stipulates, alternative panic exit devices can be assessed based on a pilot scale test if a similar panic exit device was tested in a full-scale doorset. It has been confirmed by a review of the specifications that the proposed alternative panic exit devices are similar in construction to the panic exit device tested in full scale. Based on the above, the proposed alternative panic exit devices are positively assessed.

5.10.3 Conclusion

Based on the discussion above, it is the opinion of this laboratory that the panic exit devices listed in Table 20 can achieve the indicated FRL when fitted to the referenced E-core doorsets.

Table 20 Fire resistance level of panic exit devices installed in old and new generation E-core doorsets

Item	Model	Description	Reference doorset as defined in Table 2 and Table 3	FRL
1.	Davcor F5000V VERTICAL ROD	Panic exit device	B	-/30/30
			D, E	-/120/30
2.	Davcor F5000R-AF RIM	Panic exit device	B	-/30/30

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

			D, E	-/120/30

Notes:

- The listed FRL is the maximum FRL assigned to the hardware. The system FRL needs to be determined in conjunction with the FRL of the referenced doorset. The lowest index between the FRL of the hardware and doorset will be the applicable FRL of any particular combination. Therefore, this report needs to be read in conjunction with the referenced reports listed in Table 2 and Table 3.
- The FRLs provided in this table are contingent upon the validity of the assessment reports FAS200350, FCO 3430 and FCO 3501.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

6.0 Summary of assessments

The door hardware assessed in this report and their reference outcome table are summarised in Table 21.

Table 21 Summary of assessment

Hardware	Reference table
Locksets	Table 13
Door closers	Table 14
Electric strikes	Table 15
Other locks, latches or bolts	Table 16
Eye viewer	Table 17
Additional furniture	Table 18
Hinges	Table 19
Panic exit devices	Table 20

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC

7.0 Validity

- The conclusions of this assessment may be used to directly assess the fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- Because of the nature of fire resistance testing, and the consequent difficulty in quantifying the uncertainty of measurement, it is not possible to provide a stated degree of accuracy of the result. The inherent variability in test procedures, materials and methods of construction, and installation may lead to variations in performance between elements of similar construction.
- The assessment can therefore only relate to the actual prototype test specimens, testing conditions and methodology described in the supporting data, and does not imply any performance abilities of constructions of subsequent manufacture.
- This assessment is based on information and experience available at the time of preparing this report. The published procedures for the conduct of tests and the assessment of the test results are the subject of constant review and improvement and it is recommended that this report be reviewed by Jensen Hughes before the end of the validity date.
- The information in this report must not be used for the assessment of variations other than those stated in the conclusions above. The assessment is valid provided no modifications are made to the systems detailed in this report. All details of construction should be consistent with the requirements stated in the relevant test reports and all referenced documents.
- The data, methodologies, calculations and results documented in this report specifically relate to the tested specimen/s and must not be used for any other purpose. This report may only be reproduced in full. Extracts or abridgements must not be published without permission from Jensen Hughes.

Copyright ©2025 Jensen Hughes, Inc.
All Rights Reserved. T1124 PAC